

D Montageanweisung
 DK Installasjonsinstruktus
 ES Instrucciones de montaje
 F Instructions d'installation
 I Istruzioni di montaggio
 N Installationsinstruktioner
 NL Installatievoorschrift
 S Installation instruktioner
 FI Asennusohje

SP10K-1M Auxiliary Potentiometer Kit for N05xx, N10xx Non-Spring Return Direct-Coupled Damper Actuators

INSTALLATION INSTRUCTIONS

0

24 Vdc

1

SWITCH PIN	WIRE NO.	WIRE COLOR
P1	1	BLUE
P2	2	YELLOW
P3	3	WHITE

2

3

Manufactured for and on behalf of the Environmental and Combustion Controls Division of Honeywell Technologies Sàrl, Ecublens, Route du Bois 37, Switzerland by its Authorized Representative:

Automation and Control Solutions

Honeywell GmbH
Böblinger Straße 17
D-71101 Schönaich
Phone: (49) 7031 63701
Fax: (49) 7031 637493
<http://ecc.emea.honeywell.com>

Subject to change without notice. Printed in Germany

MU1B-0392GE51 R0907A